FORM A PERFORMANCE TARGETS AND ACCOMPLISHMENTS REPORTS FY 2020

LWD Name:

MANAPLA WATER DISTRICT

MFOs AND PERFORMANCE INDICATORS (1)		FY 2019 ACTUAL ACCOMPLISHMENT (2)	FY 2020 TARGET (3)	RESPONSIBLE OFFICE/UNIT (4)	FY 2020 ACTUAL ACCOMPLISHMENT (5)	ACCOMPLISHMENT RATE (6)	REMARKS (7)
A. Water Facility Service	Management						
2019 Budget:							
PI 1 (Quantity) access to potable water	Percentage of households with access to potable water against the total number of household within the	21%	22%	Office of the GM			
	coverage of the MWD.						
PI 2 (Quality) reliability of service	% of household connection receiving 24/7 supply of water.	100%	100%	Office of the GM			
PI 3 (Timeliness) Adequacy	Source Capacity of MWD to meet demands for 24/7 supply of water.	3.15 : 1	.3.09:1	Office of the GM			
PI 4 COVID-19 RESPONSE MEASURES	COVID-19 Response Measures: -Wash hands facilities -Water delivery services -Public information drives -Sanitation and hygiene activities -Issuance of health protocols -Other resiliency program/s to mitigate COVID-19	Complied	100% Compliance	Office of the GM			
B. Water Distribution Servic	e Management						
PI 1 (Quantity) NRW: NRW should not exceed 30%	% of unbilled water to water production.	20%	20%	Office of the GM			

ND PERFORMANCE INDICATORS (1)	FY 2019 ACTUAL ACCOMPLISHMENT (2)	FY 2020 TARGET (3)	RESPONSIBLE OFFICE/UNIT (4)	FY 2020 ACTUAL ACCOMPLISHMENT (5)	ACCOMPLISHMENT RATE (6)	REMARKS (7)
by PNSDW 2017. Daily chlorine residual requirement should be at least 0.3ppm at the farthest point. In case the LWD is using chlorine	All water samples passed the physical-chemical and biological tests as required during the year. Maintained at 0.3ppm chlorine residual	All water samples should pass the physical-chemical and biological tests as required during the year. Maintain at 0.3ppm chlorine residual	Office of the GM			
Average response time in hours to restore service (major repair) when there are interruptions due to line breaks and/or production equipment or facility breakdown as reflected in the Citizen's or service Charter of MWD.	24 hours	24 hours	Office of the GM			
			100 100 100			
Categories A, B & C= 1 staff for every one hundred twenty (120) service connections. Category D = 1 staff for every one hundred (100)	2294/14 164:1	2,450/16 163:1	Office of the GM			
service connectons. Reasonableness/Affordability should observe the LWUA-approved rates	Compliant with the LWUA- approved water rate	Comply with the LWUA-approved water rate	Office of the GM			
Compliance with RA No. 11032 or the Ease of Doing Business (EODB) and efficient Government Delivery Service Act of 2018.	Complied	Compliant	Office of the GM			
Percentage of customer complaints acted upon against received complaints.	100%	95%				
3. Complaints through hotline #8888 acted upon within 72 hours.	0%	0%				
 Complaints received through the MWD customer service unit within the period prescribed by ARTA and other issuances. 	260 complaints received and acted upon within the period prescribed by ARTA and other issuances.	1,000 complaints				
	All water samples during the year should pass the physical-chemical and microbiological tests as required by PNSDW 2017. Daily chlorine residual requirement should be at least 0.3ppm at the farthest point. In case the LWD is using chlorine dioxide, the allowable level should be at least 0.2 to 0.4ppm. Average response time in hours to restore service (major repair) when there are interruptions due to line breaks and/or production equipment or facility breakdown as reflected in the Citizen's or service Charter of MWD. Categories A, B & C= 1 staff for every one hundred twenty (120) service connections. Category D = 1 staff for every one hundred (100) service connectons. Reasonableness/Affordability should observe the LWUA-approved rates 1. Compliance with RA No. 11032 or the Ease of Doing Business (EODB) and efficient Government Delivery Service Act of 2018. 2. Percentage of customer complaints acted upon against received complaints. 3. Complaints through hotline #8888 acted upon within 72 hours. 4. Complaints received through the MWD customer service unit within the period prescribed by ARTA and	ACCOMPLISHMENT (1) All water samples during the year should pass the physical-chemical and microbiological tests as required by PNSDW 2017. Daily chlorine residual requirement should be at least 0.3ppm at the farthest point. In case the LWD is using chlorine dioxide, the allowable level should be at least 0.2 to 0.4ppm. Average response time in hours to restore service (major repair) when there are interruptions due to line breaks and/or production equipment or facility breakdown as reflected in the Citizen's or service Charter of MWD. 2294/14 Categories A, B & C = 1 staff for every one hundred twenty (120) service connections. Category D = 1 staff for every one hundred (100) service connectons. Reasonableness/Affordability should observe the LWUA-approved rates 1. Compliance with RA No. 11032 or the Ease of Doing Business (EODB) and efficient Government Delivery Service Act of 2018. 2. Percentage of customer complaints acted upon against received complaints. 3. Complaints through hotline #8888 acted upon within 72 hours. 4. Complaints received through the MWD customer service unit within the period prescribed by ARTA and other	ND PERFORMANCE INDICATORS (1) All water samples during the year should pass the physical-chemical and microbiological tests as required by PNSDW 2017. Daily chlorine residual requirement should be at least 0.3ppm at the farthest point. In case the LWD is using chlorine dioxide, the allowable level should be at least 0.2 to 0.4ppm. All water samples passed the physical-chemical and biological tests as required during the year. Maintained at 0.3ppm chlorine residual residual residual ests as required during the year. Maintained at 0.3ppm chlorine residual All water samples should pass the physical-chemical and biological tests as required during the year. Maintained at 0.3ppm chlorine residual All water samples passed the physical-chemical and biological tests as required during the year. Maintained at 0.3ppm chlorine residual All water samples passed the physical-chemical and biological tests as required during the year. Maintained at 0.3ppm chlorine residual 2.4 hours 2.4 hours	ACCOMPLISHMENT (1) All water samples during the year should pass the physical-chemical and microbiological tests as required by PNSUW 2017. Daily chlorine residual requirement should be at least 0.3 pm at the farthest point. In case the LWD is using chlorine dioxide, the allowable level should be at least 0.2 to 0.4 pm. Average response time in hours to restore service (major repair) when there are interruptions due to line breaks and/or production equipment or facility breakdown as reflected in the Citizen's or service Charter of MWD. 2294/14 2.450/16 Category D = 1 staff for every one hundred twenty (120) service connections. Category D = 1 staff for every one hundred (100) service connectons. Reasonableness/Affordability should observe the LVUA-approved rates 1. Compliance with RA No. 11032 or the Ease of Doing Business (EODB) and efficient Government Delivery Service Act of 2018. 2. Percentage of customer complaints acted upon within 12 hours. 2. Compliants through hotline #8888 acted upon within 12 hours. 2. Percentage of customer ceview dhrough the MWD customer service unit within the period prescribed by ARTA and other issuances.	ND PERFORMANCE INDICATORS (1) All water samples during the year should pass the physical chemical and microbiological tests as required by PNSDW 2017. All water samples passed the physical chemical and microbiological tests as required during the year. All water samples passed the physical chemical and biological cest as as required during the year. Maintained at 0.3ppm chlorine residual requirement should be at least 0.3ppm at the farthest point. In case the LWD is using chlorine residual requirement should be at least 0.3ppm at the farthest point. In case the LWD is using chlorine residual All water samples passed the physical chemical and biological tests as required during the year. Maintained at 0.3ppm chlorine residual All water samples should pass the physical chemical and biological tests as required during the year. Maintain at 0.3ppm chlorine residual All water samples should pass the physical chemical and biological tests as required during the year. Maintain at 0.3ppm chlorine residual Office of the GM Office of the GM	NO PERFORMANCE INDICATORS ACCOMPUSIMENT (2) ACCOMPUSIMENT (3) All water samples during the year should pass the physical-chemical and microbiological tests as required and microbiological tests as required during the year evaluate requirement should be at least 0.3 ppm at the farthers point. In case the LWD is simple (shorine dioxide, the allowable level should be at least 0.2 to 0.4 ppm. Average response time in hours to restore service (major repail) when there are interruptions due to line breaks and/or production equipment or facility breakdown as reflected in the Citizen's or service (Charter of MWD. 2294/14 2.450/16 All water samples should pass the physical-chemical and biological tests as required during the year water and better and provided water than the allowable level should be at least 0.2 to 0.4 ppm. Average response time in hours to restore service (major repail) when there are interruptions due to line breaks and/or production equipment or facility breakdown as reflected in the Citizen's or service Charter of MWD. 2294/14 2.450/16 Actegories A, B & C+1 staff for every one hundred (100) service connections. Category 0 = 1 staff for every one hundred (100) service connections. Category 0 = 1 staff for every one hundred (100) approved vater rate Compliant with the LWUA-approved rates Compliant with the LWUA-approved rates Compliant Service And 70.0 service Compliant Service University of the GM (100) service connections. 1. Compliance with RA No. 11032 or the Ease of Doing Business (EOB) and efficient Government Delivery Service Act of 20.0 service

MFOs AND PERFORMANCE INDICATORS (1)		FY 2019 ACTUAL ACCOMPLISHMENT (2)	FY 2020 TARGET (3)	RESPONSIBLE OFFICE/UNIT (4)	FY 2020 ACTUAL ACCOMPLISHMENT (5)	ACCOMPLISHMENT RATE (6)	REMARKS (7)
General Administration and Su	upport Services(GASS)						
2019 Budget:						T	
PI 1 Financial Viability and Sustainability	Collection Efficiency ≥ 90%	Collection Efficiency=97%	Collection Efficiency=94%	Office of the GM		†	
	Positive Net Balance in the Average Net Income for twelve (12) months	Ave Net Income= P471,421.96	Ave Net Income= P64,050.52				
	Current Ratio = < 1.5:1	Current Ratio = 13.25:1	Current Ratio = 15:1				
	Follow the prescribed content and period of submission of five financial reports	100%	Compliant	Office of the GM			
a. Compliance with COA reporting requirements in accordance with content and period of submission.	The 5 Financial Reports: -Statement of Financial Position -Statement of Comprehensive Income -Statement of Cashflows -Statement of Changes in Equity -Notes to Financial Statements	1 report/month (12 reports annually) for Statement of Financial Position, Statement of Comprehensive Income, Statement of Cash Flows, 1 report Statement of Changes in Equity, 1 report Notes to Financial Statement	Submit the Annual Financial Reports for Statement of Financial Position, Statement of Comprehensive Income, Statement of Cashflows, Statement of Changes in Equity and Notes to Financial Statements before February 14, 2020	Office of the GM			
b. Compliance with LWUA	b. Compliance with LWUA reporting requirements in accordance to content and period of submission	100%	100%	Office of the GM			
eporting requirements in accordance to content and period of submission	i.e. Monthly Data Sheet, Balance Sheet, Income Statement, Cash Flow Statement, Microbiological/Physical/Chemical/Chlorine residual report, Approved WD budget with Annual Procurement Plan, Annual Report	Submitted 1 report/month (12 annual reports) for each of the reporting requirements as indicated herein.	Submit 1 report/month (12 annual reports) for each of the reporting requirements as indicated herein.	Office of the GM			

Prepared by:

Approved by:

Sezreel Consulta

PBB Focal Person